



May 13, 2022

Dundurn Rural Water Utility
P.O. Box 442
DUNDURN, SK S0K 1K0

Dear Waterworks Owner/Operator:

This letter is to advise you that a Precautionary Drinking Water Advisory (PDWA), has been placed on the Dundurn Rural Water Utility's distribution system (Grasswood Estates subdivision only), and **is effective Friday, May 13, 2022 at 12:30 pm** until further notice.

The Water Security Agency's protocol is to place systems under a PDWA if they experience a depressurization of the waterworks system until such a time as their entire system is proven safe for human consumptive use. This Precautionary Drinking Water Advisory is due to a depressurization of the distribution line, caused by a water main break/repair, and remains in effect until the safety of the Dundurn Rural Water Utility's distribution system can be ensured to be safe at all times. Therefore, I ask that the administration notify all affected users of the drinking water distribution system, of the conditions in the attached Precautionary Drinking Water Advisory.

This advisory can be rescinded following:

- 1) The repair work has been completed, and the line re-pressurized.
- 2) The distribution system is disinfected and flushed according to applicable standards.
- 3) The receipt of two (2) consecutive sets of two (2) bacteriological samples (4 samples in total) collected one day apart and marked as "other" along with chlorine and turbidity results, that are negative for bacteriological growth in the final treated potable water being supplied throughout the distribution system mentioned above.

Thank you for your cooperation in this regard. For further information please do not hesitate to contact the undersigned at (306) 230-3254.

Sincerely,

A handwritten signature in black ink, appearing to read "Lee Reinhart".

Lee Reinhart
Environmental Project Officer
Environmental and Municipal Management Services Division, Water Security Agency
Saskatoon, SK.

cc. Greg Holovach Manager, Environmental and Municipal Management Services Division, Water Security Agency
Brent Latimer, Michael Newell, PHI, Saskatchewan Health Authority, Saskatoon
Water Security Agency, Regina
Water Security Agency – Communications Branch