



September 21, 2022

Dundurn Rural Water Utility
P.O. Box 442
DUNDURN, SK S0K 1K0

Dear Waterworks Owner/Operator:

RE: Rescinding of Precautionary Drinking Water Advisory

Please be advised that the Water Security Agency is rescinding the Precautionary Drinking Water Advisory (PDWA) for the Dundurn Rural Water Utility's distribution system (Phase 3; 1-B Line only), which was issued on September 19, 2022, effective immediately this 21st Day of September, 2022.

The repair work has been completed, the line re-pressurized and all necessary samples have been taken and have come back with good results. No positive bacteria were found in the two sets of samples. All of the proper measures have been taken to put the distribution system back into service.

In consultation with the Saskatchewan Health Authority, by way of this letter, we agree no potential health risk currently exists for the Dundurn Rural Water Utility's distribution system, in the affected area mentioned above, and the advisory previously issued is hereby removed.

If you have any further questions or concerns, please do not hesitate to contact me at (306) 230-3254.

Sincerely,

A handwritten signature in black ink that reads "Lee Reinhart".

Lee Reinhart
Senior Environmental Project Officer
Compliance Promotion – Science & Licensing Division, Water Security Agency
Saskatoon, SK.

cc. Greg Holovach, Manager, Compliance Promotion – Science & Licensing Division, Water Security Agency
Brent Latimer, Michael Newell, PHI, Saskatchewan Health Authority, Saskatoon
Water Security Agency, Regina
Water Security Agency, Communications Division